

## EU Declaration of Conformity

issued under the sole responsibility of the manufacturer

The object of this declaration: Pressure transmitters **PC-29A, PC-29B, PC-29PA, PC-29PB** and differential pressure transmitters **PR-29A, PR-29B**.

Manufacturer: **APLISENS S.A.,  
ul. Morelowa 7,  
03-192 Warszawa**

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Pressure transmitters **PC-29A, PC-29B, PC-29PA, PC-29PB** and differential pressure transmitters type **PR-29A, PR-29B** in all versions comply with directives:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A. The following standard was applied: EN 61326-1:2013.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and of the Council.

The following standard was applied: EN 50581:2012.

Pressure transmitters and differential pressure transmitters **PC-29A, PC-29B, PC-29PA, PC-29PB, PR-29A, PR-29B** in intrinsically safe versions comply with directive:

- **ATEX – 2014/34/EU** dated 26 February 2014

Transmitters in intrinsically safe versions are marked with the following certificate marking:

II 1/2G Ex ia IIC T4/T5 Ga/Gb  
I M1 Ex ia I Ma  
FTZU 10 ATEX 0295X

Certificate (Module B) was issued by Notified Body no.1026, Physical Technical Testing Institute, Pikartska 1337/7, 716 07 Ostrava Radvanice.

The following standards were applied: EN 60079-0:2012+A11:2013, EN 60079-11:2012, EN 50303:2000.

Notification of quality assurance is issued (Module D) by Notified Body no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Warsaw, 21.07.2017



Adam Żurawski  
General Manager